

HOOD LISTING AND APPROVAL REFERENCE

EL HOOD

INTERTEK TESTING SERVICES, INC.

THE EL HOOD IS E.T.L. LISTED: EXHAUST HOODS WITHOUT EXHAUST DAMPERS, REPORT NO. 3192993CRT-002. TESTED TO U.L. STANDARD 710 REQUIREMENTS.



NATIONAL FIRE PROTECTION ASSOCIATION

MEETS ALL REQUIREMENTS OF NFPA-96
"STANDARD FOR VENTILATION CONTROL & FIRE PROTECTION OF COMMERCIAL COOKING OPERATIONS"

ETL-SANITATION LISTED

MEETS ALL REQUIREMENTS OF NSF STANDARD NO. 2
"FOOD SERVICE EQUIPMENT"



Intertek
42106

MECHANICAL CODES

MEETS ALL REQUIREMENTS OF THE UMC, BOCA, SBCCI, AND IMC.

OPTIONAL DCA BOX

INCLUDES: DCA CONTROLLER AND CANOPY MOUNTED RTD.
SYSTEM IS DESIGNED TO AUTOMATICALLY START EXHAUST/SUPPLY FANS.
COMPLIES WITH IMC 507.2.1.1.